



RE: 907188 Pine View Estates 

Aaron Setran to: David Wallis

08/11/2009 09:00 AM



Aaron Setran

yes, we're going to have to have a serious discussion w/ the lab on this

b5

Aaron Carr Setran
U.S. EPA, Water Division
75 Hawthorne St.
San Francisco, CA 94105
(415) 972-3457

"David Wallis" <DWallis@rcac.org>

"David Wallis" <DWallis@rcac.org>

08/11/2009 06:13 AM

To

Aaron Setran/R9/USEPA/US@EPA

cc

Subject

RE: 907188 Pine View Estates

Aaron,

The influent BOD at 1100 mg/L is pretty much off the chart for normal domestic wastewater loading- I would have anticipated a 150-300 mg/L range

Dave

-----Original Message-----

From: Setran.Aaron@epamail.epa.gov [<mailto:Setran.Aaron@epamail.epa.gov>]

Sent: Monday, August 10, 2009 4:04 PM

To: David Wallis

Subject: Fw: 907188 Pine View Estates

fyi: results look better than previous months, except TKN.

Aaron Carr Setran
U.S. EPA, Water Division
75 Hawthorne St.

San Francisco, CA 94105
(415) 972-3457

----- Forwarded by Aaron Setran/R9/USEPA/US on 08/10/2009 04:03 PM -----

"Cassie
Cummings"
<cassiec@wetlabo
ratory.com>

Aaron Setran/R9/USEPA/US@EPA

To

cc

08/10/2009 03:54
PM

Subject

907188 Pine View Estates

Cassie Cummings

Western Environmental Testing Laboratory
775-355-0202 (phone)
775-355-0817 (fax)
cassiec@wetlaboratory.com(See attached file: 907188 Pine View
Estates.pdf)

